

Monday Afternoon  
Riverside, NJ  
December 8, 2025  
**Regular Meeting**  
4:30pm

**STATEMENT:**

Public Notice of this meeting pursuant to the Open Public Meetings Act has been given by the Riverside Sewerage Authority in the following manner:

- 1) Posting written notice on the official bulletin board at the Township Administrative Office Building on February 20, 2025.
- 2) Written notice was delivered to the Burlington County Times and the Courier Post on February 20, 2025.
- 3) Filed written notice with the Clerk of the Township of Riverside on February 20, 2025.

The Regular Meeting of the Riverside Sewerage Authority was held at the Riverside Township Municipal Building.

**FLAG SALUTE:**

Chairman Giovanetti led the Flag Salute.

**ROLL CALL:**

Mr. Brickley – present, Mr. George Conard – present, Mr. Giovanetti–present, Mr. Horton – present, Mr. Mingin – present.

Also present: Authority Secretary Susan M. Dydek, Authority Treasurer Meghan Jack, and Superintendent Jeffrey Conard.

**APPROVAL OF MINUTES:**

Motion made by Mr. Conard, seconded by Mr. Mingin that the minutes of the Work Session Meeting of November 10, 2025, the Regular Meeting of November 10, 2025 and the Special Meeting of November 24, 2025 be approved. Upon roll call the vote was as follows: Ayes – Messrs. Conard, Horton, Giovanetti and Mingin. Nays – None. Abstain – Mr. Brickley. Absent – None. Motion carried.

Motion made by Mr. Brickley, seconded by Mr. Conard that the minutes of the Special Meeting of November 24, 2025 be approved carried.

**RESOLUTIONS:**

Motion made by Mr. Horton that Resolution 2025 - #29 entitled, “A Resolution of the Riverside Sewerage Authority Authorizing the Cancellation of Sewer Overpayments or Delinquent Amounts Less Than \$10.00” be approved seconded by Mr. Mingin. Upon roll call the vote was as follows: Ayes – Messrs. Brickley, Conard, Giovanetti, Horton, and Mingin. Nays – None. Abstain – None. Absent – None. – None. Motion carried.

Motion made by Mr. Conard that Resolution 2025 - #30 entitled, "Adoption of the 2026 Authority Budget" be approved seconded by Mr. Brickley. Upon roll call the vote was as follows: Ayes – Messrs. Brickley, Conard, Giovanetti, Horton, and Mingin. Nays – None. Abstain – None. Absent – None. – None. Motion carried.

Motion made by Mr. Brickley that Resolution 2025 - #31 entitled, "Resolution for Salary Increase" be approved seconded by Mr. Conard. Upon roll call the vote was as follows: Ayes – Messrs. Brickley, Conard, Giovanetti, Horton, and Mingin. Nays – None. Abstain – None. Absent – None. – None. Motion carried.

Motion made by Mr. Conard that Resolution 2025 - #32 entitled, "A Resolution of the Riverside Sewerage Authority Authorizing the Treasurer for Salary Increase" be approved seconded by Mr. Horton. Upon roll call the vote was as follows: Ayes – Messrs. Brickley, Conard, Giovanetti, Horton, and Mingin. Nays – None. Abstain – None. Absent – None. – None. Motion carried.

**PUBLIC PORTION – (TECHNICAL):**

In seeing no members of the Public Present wishing to speak, Motion made by Mr. Conard, seconded by Mr. Mingin to close Public Portion (Technical) carried.

**OLD BUSINESS:**

None.

**NEW BUSINESS:**

- 1) Kelly Mercado – 200 Rancocas Avenue – Please check main, sewer line is backing up.
- 2) (Anonymous) – sewer line leaking at 403 Kossuth Street for a week.
- 3) Kimberly Petka – Adjustment request – 11 and 13 Lafayette Street – **Motion made to deny the adjustment request since the Authority advertises that residents should contact the Riverside Sewerage Authority before hiring a plumber made by Mr. Horton and Mr. Conard carried.**

**CORRESPONDENCE:**

- 1) Cheryl Hardie – Retirement Notice

**REPORTS:**

**PLANT:**

Mr. Giovanetti stated that the report will be given in the Superintendent's Report.

**APPEALS**

Mr. Mingin had nothing to report.

**RESOLUTION 2025 - #29**  
**A RESOLUTION OF THE RIVERSIDE SEWERAGE AUTHORITY**  
**AUTHORIZING THE CANCELLATION OF SEWER OVERPAYMENTS OR**  
**DELINQUENT AMOUNTS LESS THAN \$10.00**

**WHEREAS**, N.J.S.A. 40A:5-17 allows for the cancellation of refunds or delinquent amounts in the amounts of less than \$10.00; and

**WHEREAS**, the Riverside Sewerage Authority may authorize a municipal employee chosen by said body to process, without further action on their part, any cancellation of refunds or delinquencies of less than \$10.00.

**NOW, THEREFORE, BE IT RESOLVED**, by the Riverside Sewerage Authority that the Riverside Township Tax Collector is authorized to cancel said amounts as deemed necessary for the tax year 2025

**I HEREBY CERTIFY** that the foregoing Resolution was adopted by the Riverside Sewerage Authority of the Township of Riverside, in the Township of Riverside, County of Burlington, State of New Jersey, at a Regular Meeting held on December 8, 2025.

Authority Member	Motion	2 <sup>nd</sup>	Yes	Abstain	No	Absent
<b>Brickley</b>			X			
<b>Conard</b>			X			
<b>Giovanetti</b>			X			
<b>Horton</b>	1st		X			
<b>Mingin</b>		2nd	X			

**CERTIFICATION**

I, Susan M. Dydek, RMC, Authority Secretary, hereby certify that the foregoing Resolution was duly adopted by the Riverside Sewerage Authority, in the Township of Riverside, County of Burlington, State of New Jersey, at the Regular Meeting held on the 8th day of December, 2025.

  
Susan M. Dydek, RMC  
Authority Secretary

**RIVERSIDE SEWERAGE AUTHORITY**  
**RESOLUTION 2025 - #30**

ADOPTION OF THE 2026 AUTHORITY  
BUDGET.

**BE IT RESOLVED**, that the Budget for the  
Calendar Year 2026 is hereby adopted.

Authority Member	Motion	2 <sup>nd</sup>	Yes	Abstain	No	Absent
<b>Brickley</b>		2 <sup>nd</sup>	X			
<b>Conard</b>	1st		X			
<b>Giovanetti</b>			X			
<b>Horton</b>			X			
<b>Mingin</b>			X			

**CERTIFICATION**

I, Susan M. Dydek, RMC, Authority Secretary, hereby certify that the foregoing Resolution was  
duly adopted by the Riverside Sewerage Authority, in the Township of Riverside, County of  
Burlington, State of New Jersey, at the Regular Meeting held on the 8th day of December, 2025.

  
Susan M. Dydek, RMC  
Authority Secretary

**RESOLUTION 2025 - #31**  
**RIVERSIDE SEWERAGE AUTHORITY**  
**RESOLUTION FOR SALARY INCREASE**

**WHEREAS**, the Riverside Sewerage Authority has adopted the 2026 Budget; and

**WHEREAS**, the Treasurer has certified that funds are available for an increase in the salaries of certain employees of the Riverside Sewerage Authority; and

**WHEREAS**, it is the desire of the Riverside Sewerage Authority to increase the pensionable salaries of the following positions by three and a half percent (3.5%) for the calendar year 2026: the Treasurer, Assistant Treasurer, Secretary, Billing Clerk; Clerk and

**WHEREAS**, the Riverside Sewerage Authority recognizes that certain employees' salaries are contractual and will abide by the contractual increases of said applicable employees.

**NOW, THEREFORE, BE IT RESOLVED**, by the Riverside Sewerage Authority that the pensionable salaries of the Treasurer, Assistant Treasurer, Secretary, Billing Clerk and Clerk shall be increased by the aforementioned amounts and the salary increases of the applicable contractual employees shall increase by the terms of their contract.

Authority Member	Motion	2 <sup>nd</sup>	Yes	Abstain	No	Absent
<b>Brickley</b>	1st		X			
<b>Conard</b>		2nd	X			
<b>Giovanetti</b>			X			
<b>Horton</b>			X			
<b>Mingin</b>			X			

**CERTIFICATION**

I, Susan M. Dydek, RMC, Authority Secretary, hereby certify that the foregoing Resolution was duly adopted by the Riverside Sewerage Authority, in the Township of Riverside, County of Burlington, State of New Jersey, at the Regular Meeting held on the 8th day of December, 2025.

  
\_\_\_\_\_  
Susan M. Dydek, RMC  
Authority Secretary

**RESOLUTION 2025 - #32**

**A RESOLUTION OF THE RIVERSIDE SEWERAGE AUTHORITY AUTHORIZING THE TREASURER THE "AUTHORITY" TO PAY ALL BILLS THROUGH THE END OF THE YEAR.**

**WHEREAS**, the Riverside Sewerage Authority is holding their final regular public meeting of the year on December 8, 2025; and

**WHEREAS**, notwithstanding prior transfers and to assure that all 2025 budget appropriations have adequate funds to support the Riverside Sewerage Authority's activities through year-end, the Riverside Sewerage Authority hereby authorizes that the Treasurer be delegated the "authority" to make additional transfers of funds, if required; and

**WHEREAS**, the Riverside Sewerage Authority authorizes that the Treasurer has the authority to pay all necessary bills through year end.

**NOW, THEREFORE, BE IT RESOLVED**, by the Riverside Sewerage Authority located in the Township of Riverside, County of Burlington, State of New Jersey, that the Treasurer is hereby delegated the authority to make transfers of funds in the 2025 budget and pay all necessary bills and expenditures to assure uninterrupted Sewerage Authority operations with ratification by the Riverside Sewerage Authority at the next Sewerage Authority Meeting.

**BE IT FURTHER RESOLVED**, that all of the applicable Sewerage Authority Officers, whom are authorized to sign the checks to pay the aforementioned bills and expenditures, are hereby authorized to sign such checks.

Authority Member	Motion	2 <sup>nd</sup>	Yes	Abstain	No	Absent
<b>Brickley</b>			X			
<b>Conard</b>	1st		X			
<b>Giovanetti</b>			X			
<b>Horton</b>		2nd	X			
<b>Mingin</b>			X			

**CERTIFICATION**

I, Susan M. Dydek, RMC, Authority Secretary, hereby certify that the foregoing Resolution was duly adopted by the Riverside Sewerage Authority, in the Township of Riverside, County of Burlington, State of New Jersey, at the Regular Meeting held on the 8th day of December, 2025.

  
\_\_\_\_\_  
Susan M. Dydek, RMC  
Authority Secretary

**REVENUE AND FINANCE:**

Mr. Horton had nothing to report.

**STREETS:**

No report was given due to the vacancy.

**INSPECTIONS:**

Mr. Conard had nothing to report.

**EXECUTIVE DIRECTOR'S REPORT:**

Executive Director Jeffrey Conard reported on the following:

- Digester rig installed, awaiting a relief valve to put it in service (expected end of December or January).
- Grit chamber #1 cleaned; repairs are underway and deemed necessary for plant operations.
- Update on ongoing yard excavation to connect main lines and improve influent management.
- Plant process modifications detailed, including re-routing grit handling and upgrades to ceramic impellers.
- Project timelines: headworks project submitted as separate under plant upgrades; deadlines aligned for DEP review and H2O loan application. Full project submission expected by late December or early January.
- Awaiting an electric survey report from Pennoni; payments are withheld until deliverable is received. No objections from the Authority.
- Grit project will not go to bid until May 2026; likely start date is spring 2027 due to long manufacturing lead times.
- Maintenance updates: pump repairs at Lichenthal station underway, UVT issues in clarifiers continue to be addressed.
- Both the Executive Director and the Treasurer expressed satisfaction with ERI's progress.

The report is on file in the Secretary's Office.

**Motion made by Mr. Horton to accept the Executive Director's Report, seconded by Mr. Conard carried.**

**ENGINEER'S REPORT:**

The Engineer's Report was not submitted.

**MONTHLY FINANCIAL REPORT:**

Treasurer Jack reported on a potential upcoming budget amendment; will consult with accountant and auditor, updates to follow if necessary.

**BILLS AND EXPENDITURES:**

Motion made by Mr. Horton, seconded by Mr. Mingin that all bills and expenditures be paid carried.

Riverside Sewerage Authority

Range of Checking Accts: 01 TD GENERAL to 01 TD GENERAL Range of Check Ids: 5444 to 5466  
 Report Type: All Checks Report Format: Super Condensed Check Type: Computer: Y Manual: Y Dir Deposit: Y

Check #	Check Date	Vendor	Amount Paid	Reconciled/Void Ref Num
5444	12/08/25	ALSEN005 ALS ENVIRONMENTAL	426.00	352
5445	12/08/25	ALSEN005 ALS ENVIRONMENTAL	528.50	352
5446	12/08/25	ALSEN005 ALS ENVIRONMENTAL	2,243.00	352
5447	12/08/25	CHEMS010 CHEMSEARCHFE	1,003.45	352
5448	12/08/25	CUSTO005 CUSTOM ENVIRONMENTAL TECH-	5,699.85	352
5449	12/08/25	EMSLA005 EMSL ANALYTICAL INC	110.00	352
5450	12/08/25	GANNE001 GANNETT NEW YORK-NEW JERSEY IQ	42.32	352
5451	12/08/25	GRAIN005 GRAINGER	685.24	352
5452	12/08/25	LONGO005 LONGO ELECTRICAL CONTROLS LLC	15,107.28	352
5453	12/08/25	LOUIS005 LOUIS VAZQUEZ	100.00	352
5454	12/08/25	LOWTH005 LOWTHER'S SMALL ENGINE REPAIR	114.37	352
5455	12/08/25	MARME005 MARMERO LAW LLC	330.00	352
5456	12/08/25	MNASS005 M & N ASSOCIATES COMPANY	35,500.00	352
5457	12/08/25	NJAME005 N.J. AMERICAN WATER COMPANY	812.55	352
5458	12/08/25	PARKE005 PARKER MC CAY PA	2,586.50	352
5459	12/08/25	PRIME005 PRIMEPOINT LLC	245.60	352
5460	12/08/25	SCHWE005 SCHWERING'S	283.01	352
5461	12/08/25	UGIEN005 UGI ENERGY SERVICES LLC	100.93	352
5462	12/08/25	UNIVE005 UNIVERSAL INSTRUMENT SERV CO	813.56	352
5463	12/08/25	VERIZ005 VERIZON	76.86	352
5464	12/08/25	VERIZ010 VERIZON WIRELESS	239.95	352
5465	12/08/25	WESTE005 WESTERN TERMITE & PEST CONTROL	113.31	352
5466	12/08/25	XEROX005 XEROX CORPORATION	71.09	352

Report Totals	Paid	Void	Amount Paid	Amount Void
Checks:	23	0	67,233.37	0.00
Direct Deposit:	0	0	0.00	0.00
Total:	23	0	67,233.37	0.00

January 2, 2026  
01:03 PM

TOWNSHIP OF RIVERSIDE  
Check Register By Check Id

Page No: 1

Range of Checking Accts: 01 TD GENERAL to 01 TD GENERAL Range of Check Ids: 20251 to 20267  
Report Type: All Checks Report Format: Super Condensed Check Type: Computer: Y Manual: Y Dir Deposit: Y

Check #	Check Date	Vendor	Amount Paid	Reconciled/Void Ref Num
20251	12/31/25	ACTIV010 THE ACTIVITY GROUP INC	4,378.78	1741
20252	12/31/25	BHKE005 BHK ELECTRICAL LLC	1,018.95	1741
20253	12/31/25	JOHN030 JOHN JENKINS	145.35	1741
20254	12/31/25	LOWTH010 LOWTHERS SMALL ENGINE INC.	107.45	1741
20255	12/31/25	MARME010 MARMERO LAW, LLC	9,838.00	1741
20256	12/31/25	MEGHA010 MEGHAN JACK - TREASURER	106.44	1741
20257	12/31/25	MRJOH010 United Site Services	65.63	1741
20258	12/31/25	MRJOH010 United Site Services	95.63	1741
20259	12/31/25	MRJOH010 United Site Services	65.63	1741
20260	12/31/25	NEWJE130 NEW JERSEY-AMERICAN	391.22	1741
20261	12/31/25	PSEG0010 PSE&G	7.95	1741
20262	12/31/25	PSEG0010 PSE&G	37,472.34	1741
20263	12/31/25	RIGGI005 Riggins Inc	694.75	1741
20264	12/31/25	SOUTH025 SOUTH JERSEY WELDING SUPPLY	39.68	1741
20265	12/31/25	TMOBI010 T-Mobile USA Inc	818.03	1741
20266	12/31/25	TRASH010 TRASHPRO	5,024.07	1741
20267	12/31/25	TREAS010 TREASURER - BURLINGTON COUNTY	30,175.67	1741

Report Totals	<u>Paid</u>	<u>Void</u>	<u>Amount Paid</u>	<u>Amount Void</u>
Checks:	17	0	90,445.57	0.00
Direct Deposit:	0	0	0.00	0.00
Total:	17	0	90,445.57	0.00

**RIVERSIDE SEWERAGE AUTHORITY  
PLANT OPERATOR'S REPORT  
AUTHORITY MEETING – December 8, 2025**

1. The Plant Performance Summary for October, 2025 is attached for review. The Residuals [Sludge] Management Summary for October, 2025 is also attached for review. Dewatered sludge [25 yds] were removed by the Seaside Waste Services Company for composting at the County facility.
2. Trouble log for November is attached.
3. Weekly collection system checks were performed in November.
4. No measurements were taking for the Secondary Digester Cover tilt during this reporting period. The Secondary Digester is not operating as designed. The Secondary Digester Dome requires methane gas produced in the Primary Digester for the secondary roof to float correctly.
5. Still injecting Poly Aluminum Chloride in the influent well of the flocs to assist with suspended solids settling out. This will assist in keeping our UVT number above 43 which is the lowest number for our UV system to function properly.
6. Digester lid has been installed. Still waiting on the relief valve to come in.
7. Grit Chamber #1 was cleaned and evaluated for repair. Cost is estimated to be in the 30k -40k area. I authorized Municipal Maintenance to start the necessary repairs.
8. M&N will be digging an exploratory hole to look into combining both influent lines at one point in the area of the grit pad.
9. Pump #1 at Lichenthal Pump Station has been rebuilt. Pump #2 is set to be rebuilt in January.

Respectfully Submitted,



JEFFREY M. CONARD  
EXECUTIVE DIRECTOR

## November 2025 Trouble Log Summary

<i>Date</i>	<i>Report #</i>	<i>Address</i>	<i>Condition(s) Reported</i>	<i>Condition(s) Found</i>	<i>Manhole Checked</i>	<i>Disposition</i>
11/3/2025	25-087	Madison and Monroe	Markout	Emergency	MH45,46,47	Marked out 150 feet /NJAW
11/6/2025	25-088	219 Cleveland Ave	Vent overflow	Main Clear	MH323,451	Notified owner/tenant
11/12/2025	25-089	Carrol & Rush St	Vent overflow	Main Slow	MH184,185	Flush/Vac/Root cut sewer main
11/13/2025	25-090	200 Rancocas Ave	line inspection	Main Clear	MH312,328,329	Notified owner/tenant
11/14/2025	25-091	Tyler & Pavilion	Markout	Emergency		Marked main
11/14/2025	25-092	Carrol & Rush St	Backflow to property	Main Slow	MH184,185	Flush/Vac/Root cut sewer main
11/15/2025	25-093	154 Webster	Mark out	emergency mark out	MH170,171	Marked main
11/15/2025	25-094	Madison & Laffette	Slow/no drainage	Main slow	MH37,52,51,49	Flush/Vac/Root cut sewer main
11/15/2025	25-095	212 American Legion Dr	Backflow to property	Main Clear	MH13,14,15	Notified owner/tenant
11/17/2025	25-096	400 East Washington	Locate Vent	Main Clear	MH102,107	Notified owner/tenant
11/18/2025	25-097	4th and Cleveland	Line maintenance	Main Slow	MH300,318,452	Flush/Vac/Root cut sewer main
11/18/2025	25-098	403 Kossuth St	Vent overflow	Main Slow	MH100,111	Flush/Vac/Root cut sewer main
11/18/2025	25-099	Fairview 200 block	Slow/ no drainage	Main slow/Debris in MH	MH322,321	Flush/Vac/Root cut sewer main
11/21/2025	25-100	8 Spring Garden St	Vent overflow	Main Clear	MH175,176,177	Notified owner/tenant
11/20/2025	25-101	403 Kossuth St	Vent overflow	Main Slow	MH100,111	Flush/Vac/Root cut sewer main
11/24/2025	25-102	412 Kossuth St	Vent overflow	Main Clear	MH100,111	Notified owner/tenant

**Case# 25-1124-1118-53**

## PLANT PERFORMANCE SUMMARY

October-25

PARAMETER	PERMIT	REPORTED	PARAMETER	PERMIT	REPORTED
12 Month rilling avg. Flow					
Monthly Avg	Report	0.640 MGD	Mon Avg Conc	Report	63.90 MG/L
FLOW, INFLUENT			NITRATE (AS N), EFFLUENT Monthly		
Monthly Avg	Report	0.844 MGD	Mon Avg Conc	Report	27.80 MG/L
Daily Maximum	Report	1.112 MGD	Daily Max Conc	Report	27.80 MG/L
FLOW, EFFLUENT			E. COLI 2 / month		
Monthly Avg	Report	0.643 MGD	Monthly Avg	Report	43.77 /100ML
Daily Maximum	Report	0.812 MGD	Instant Max	Report	58.60 /100ML
5 DAY BOD, INFLUENT 3/month			FECAL COLIFORM, EFFLUENT Require Reuse Only		
Mon Avg Conc	Report	237.97 MG/L	Monthly Avg	200/100ML	179.00 /100ML
Weekly Avg Conc	Report	438.00 MG/L	Weekly Avg	400/100ML	179.00 /100ML
5 DAY BOD, EFFLUENT 3/month			BIOASSAY, EFFLUENT		
Mon Avg Loading	98 KG/D	18.66 KG/D	LC50 96 hr Acute	50	0.00 %
Weekly Avg Loading	147 KG/D	21.62 KG/D	IC25 7 day Chronic	Report	0.00 %
Mon Avg Conc	30 MG/L	8.28 MG/L	CHLORINE PRODUCED OXIDANTS, EFFLUENT Monthly		
Weekly Avg Conc	45 MG/L	10.20 MG/L	Mon Avg Conc	Report	0.02 MG/L
5 DAY BOD REMOVAL EFFICIENCY 3/month			Daily Max Conc	Report	0.03 MG/L
Mon Avg Minimum	88.5	95.24 %	TEMPERATURE, INFLUENT Daily		
pH, INFLUENT Daily			Minimum	Report	21.0 DEG C
Minimum	Report	6.97 S.U.	Monthly Avg	Report	22.6 DEG C
Maximum	Report	7.69 S.U.	Maximum	Report	24.5 DEG C
pH, EFFLUENT Daily			TEMPERATURE, EFFLUENT Daily		
Minimum	6.00 S.U.	6.23 S.U.	Minimum	Report	18.7 DEG C
Maximum	9.00 S.U.	7.00 S.U.	Monthly Avg	Report	20.9 DEG C
TOTAL SUSP SOLIDS, INFLUENT 3/month			Maximum	Report	24.0 DEG C
Mon Avg Conc	Report	359.7 MG/L	DISSOLVED OXYGEN, EFFLUENT 3/month		
Weekly Avg Conc	Report	693.0 MG/L	Wkly Avg Conc [Min]	4.0 MG/L	5.90 MG/L
TOTAL SUSP SOLIDS, EFFLUENT 3/month			PHOSPHOROUS, EFFLUENT 1 / month		
Mon Avg Loading	113 KG/D	20.14 KG/D	Mon Avg Conc	Report	5.1 MG/L
Weekly Avg Loading	170 KG/D	25.77 KG/D	Weekly Avg Conc	Report	5.1 MG/L
Mon Avg Conc	30 MG/L	8.87 MG/L	COPPER, EFFLUENT Quarterly only		
Weekly Avg Conc	45 MG/L	11.00 MG/L	Mon Avg Conc	Report	Code=n MG/L
TOTAL SUSP SOLIDS REMOVAL EFFICIENCY 3/month			Daily Max Conc	Report	Code=n MG/L
Mon Avg Minimum	85	96.21 %	ZINC, EFFLUENT Quarterly Only		
OIL&GREASE, EFFLUENT Quarterly			Mon Avg Conc	Report	Code=n MG/L
Mon Avg Conc	10 MG/L	Code=N MG/L	Daily Max Conc	Report	Code=n MG/L
Daily Max Conc	15 MG/L	Code=N MG/L	Total Dissolved Solids Effluent 1/month		
Ammonia-Nitrogen (May-Oct), Effluent			Mon Avg Conc	Report	546.0 MG/L
Mon Avg Loading	18.8 kg/d	12.18 KG/D	Daily Max Conc	Report	546.0 MG/L
Daily Max Loading	37.9 kg/d	36.32 KG/D	<b>Bis(2-ethylhexyl)phthalate Quarterly only</b>		
Mon Avg Conc	5 mg/l	8.94 MG/L	Mon Avg Conc	Report	1.4 ug/l
Daily Max Conc	10 mg/l	15.50 MG/L	Daily Max Conc	Report	1.4 ug/l
AMMONIA NITROGEN (NOV-APR), EFFLUENT 3/month			<b>Asbestos Fifrous per Liter Semi-Annually</b>		
Mon Avg Loading	75.7 KG/D	0.00 KG/D	Mon Avg Conc	Report	2.02 Fiber/liter
Daily Max Loading	151.4 KG/D	0.00 KG/D	Daily Max Conc	Report	2.02 Fiber/liter
Mon Avg Conc	20 MG/L	0.00 MG/L	Color Starting July 2024		
Daily Max Conc	40 MG/L	0.00 MG/L	Mon Avg Conc	Report	70.00 CU
Copper	Required	Quarterly	IC25 Chronic	Required	Semi- Annually
Zinc	Required	Quarterly	LC50 Acute	Required	Annually
Asbestos Fifrous per Liter Semi-Annually			<b>Bis(2-ethylhexyl)phthalate Quarterly</b>		

## RESIDUALS MANAGEMENT SUMMARY

October-25

SLUDGE PRODUCED			RAW SLUDGE		
Total Gallons	0	gal	% Total Solids, minimum	2.8	%
Average Gallons/Day	0	gpd	% Total Solids, average	3.1	%
Total Dry Tons	0	dt	% Total Solids, maximum	3.3	%
Average Dry Tons/ Day	0	dt/d	% Total Volatile Solids, minimum	78.4	%
Total Metric Tons	0	mt	% Total Volatile Solids, average	80.05	%
Average Metric Tons/Day	0	mt/d	% Total Volatile Solids, maximum	3.3	%
			pH minimum	4.91	s.u.
			pH maximum	6.06	s.u.
LIQUID SLUDGE REMOVED					
Total Gallons	0	gal	sludge sample temperature, min	17.6	C
Average Gallons/Day	0	gpd	sludge sample temperature, avg	21.9	C
Total Dry Tons	N.R.	dt	sludge sample temperature, max	24.3	C
Average Dry Tons/ Day	N.R.	dt/d			
Total Metric Tons	N.R.	mt	PRIMARY DIGESTER SLUDGE		
Average Metric Tons/Day	N.R.	mt/d	% Total Solids, minimum	0	%
% Total Solids, Minimum	N.R.	%	% Total Solids, average	0	%
% Total Solids, Average	N.R.	%	% Total Solids, maximum	0	%
% Total Solids, Maximum	N.R.	%	% Total Volatile Solids, minimum	0	%
pH, Minimum	N.R.	s.u.	% Total Volatile Solids, average	0	%
pH, Maximum	N.R.	s.u.	% Total Volatile Solids, maximum	0	%
			pH minimum	0	s.u.
			pH maximum	0	s.u.
DEWATERED SLUDGE REMOVED					
Total Gallons to Belt Press	0	gal	sludge sample temperature, min	0	C
Average Gallons/Day	0	gpd	sludge sample temperature, avg	0.0	C
% Total Solids, minimum	19	%	sludge sample temperature, max	0	C
% Total Solids, average	24.4	%			
% Total Solids, maximum	29.8	%	SECONDARY DIGESTER SLUDGE		
% Total Volatile Solids, minimum	78.10	%	% Total Solids, minimum	2.60	%
% Total Volatile Solids, average	78.15	%	% Total Solids, average	2.75	%
% Total Volatile Solids, maximum	78.20	%	% Total Solids, maximum	2.90	%
Total Wet Cubic Yards Removed	125	cu yd	% Total Volatile Solids, minimum	69.70	%
Average Wet Cubic yards/day	4.03	cy/d	% Total Volatile Solids, average	78.60	%
Total Dry Tons	24.11	dt	% Total Volatile Solids, maximum	87.50	%
Average Dry Tons/ Day	0.78	dt/d	pH minimum	5.40	s.u.
Total Metric Tons	21.92	mt	pH maximum	6.51	s.u.
Average Metric Tons/Day	0.71	mt/d	sludge sample temperature, min	17.8	C
			sludge sample temperature, avg	19.8	C
			sludge sample temperature, max	22.9	C
OPERATIONS					
Heat Exchange, Temp In, min	0.0	<sup>0</sup> F	VOLATILE SOLIDS REDUCTION		
Heat Exchange, Temp In, avg	0.0	<sup>0</sup> F	Raw to Secondary Digester, minimum		%
Heat Exchange, Temp In, max	0.0	<sup>0</sup> F	Raw to Secondary Digester, average		%
Heat Exchange, Temp Out, min	0.0	<sup>0</sup> F	Raw to Secondary Digester, maximum		%
Heat Exchange, Temp Out, avg	0.0	<sup>0</sup> F			
Heat Exchange, Temp Out, max	0.0	<sup>0</sup> F			
Detention Time, Primary Digester	0	days			
Detention Time, Secondary Digester	0	days			
N.R. = None Removed			R.T.S. = Return To Service		
N.S. = Not Sampled			N.I.S. = Not In Service		
N.W. = Not Working					

**PUBLIC PORTION (INFORMATIONAL):**

In seeing that no members of the public wishing to speak, **motion made by Mr. Conard and Mr. Brickley that Public Portion (Informational) be closed carried.**

**There being no further business to attend to, motion made by Mr. Conard and Mr. Brickley that the meeting be adjourned, and so declared by Chairman Giovanetti.**

  
Susan M. Dydek, RMC  
Authority Secretary

Riverside Sewerage Authority