

Monday Afternoon
Riverside, NJ
July 13, 2026
Regular Meeting
4:30pm

STATEMENT:

Public Notice of this meeting pursuant to the Open Public Meetings Act has been given by the Riverside Sewerage Authority in the following manner:

- 1) Posting written notice on the official bulletin board at the Township Administrative Office Building on February 20, 2025.
- 2) Written notice was delivered to the Burlington County Times and the Courier Post on February 20, 2025.
- 3) Filed written notice with the Clerk of the Township of Riverside on February 20, 2025.
- 4) Posting written notice on the Township Website January 12, 2026.

The Regular Meeting of the Riverside Sewerage Authority was held at the Riverside Township Municipal Building.

FLAG SALUTE:

Vice - Chairman Giovanetti led the Flag Salute.

ROLL CALL:

Mr. Brickley – not in attendance, Mr. George Conard – not in attendance, Mr. Giovanetti – present, Mr. Horton – present, Mr. Mingin – present.

Also present: Authority Secretary Susan M. Dydek, Authority Treasurer Meghan Jack and Executive Director Jeffrey Conard.

APPROVAL OF MINUTES:

Motion made by Mr. Horton, seconded by Mr. Mingin, that the minutes of the Work Session Meeting of June 8, 2026 and the Regular Meeting of June 8, 2026 be approved. Upon roll call the vote was as follows: Ayes – Messrs. Horton, Giovanetti and Mingin. Nays – None. Abstain – None. Absent – Messrs. Brickley and Conard. Motion carried.

RESOLUTIONS:

Mr. Horton made a motion to adopt Resolution 2026 - #24 entitled, "A Resolution of the Township of Riverside Authorizing to Enter into an Agreement with Phoenix Advisors, LLC seconded by Mr. Mingin be approved. Upon roll call the vote was as follows: Ayes –

RESOLUTION 2026 - #24
A RESOLUTION OF THE TOWNSHIP OF RIVERSIDE AUTHORIZING TO ENTER
INTO AN AGREEMENT WITH PHOENIX ADVISORS, LLC.

WHEREAS, the Riverside Sewerage Authority has authorized funding for Financial Advisors:
and

WHEREAS, Phoenix Advisors, LLC provides specific financial and other information with
regard to Bond and Note sales: and

WHEREAS, the Riverside Sewerage Authority has determined that there is a need for such
service.

NOW, THEREFORE, BE IT RESOLVED, that the Riverside Sewerage Authority hereby
authorizes an Agreement with Phoenix Advisors, LLC.

BE IT FURTHER RESOLVED, that the fee for services provided by Phoenix Advisors LLC
shall not exceed \$7,500.00.


EFFECTIVE DATE:

This Resolution shall take effect immediately upon passage.

Authority Member	Motion	2 nd	Yes	Abstain	No	Absent
Brickley						X
Conard						X
Giovanetti			X			
Horton	1st		X			
Mingin		2nd	X			

CERTIFICATION

I, Susan M. Dydek, RMC, Authority Secretary, hereby certify that the foregoing Resolution was
duly adopted by the Riverside Sewerage Authority, in the Township of Riverside, County of
Burlington, State of New Jersey, at the Regular Meeting held on the 13th day of July, 2026.


 Susan M. Dydek, RMC
 Authority Secretary

**RESOLUTION NO. 2026 - #25
RIVERSIDE SEWERAGE AUTHORITY
A RESOLUTION AUTHORIZING THE
AWARD OF A CONTRACT FOR BOND COUNSEL**

WHEREAS, the Riverside Sewerage Authority has a need to acquire Bond Counsel Services; and

WHEREAS, the anticipated value of these services will not exceed the \$17,500.00 "Pay-to-Play" threshold; and

WHEREAS, Parker McCay PA, located at 9000 Midlantic Drive Suite 30 Mount Laurel, NJ 08054 has submitted a proposal/quote to provide Bond Counsel Services; and

WHEREAS, the Treasurer has certified that funds are available for this purpose in the budget year 2026.


NOW, THEREFORE, BE IT RESOLVED, by the Riverside Sewerage Authority as follows:

1. The Chairman is hereby authorized and directed to enter into a contract/agreement with Parker McCay in an amount not to exceed \$17,000.00.
2. The contract is awarded without competitive bidding as a professional service purchase in accordance with the Local Public Contracts Law, N.J.S.A. 40A:11-1 et seq.
3. The effective date of this Resolution is retroactive back to February 9, 2026.
4. A notice of this action shall be posted on the Township Website as required by law.

Authority Member	Motion	2 nd	Yes	Abstain	No	Absent
Brickley						X
Conard						X
Giovanetti			X			
Horton	1st		X			
Mingin		2nd	X			

CERTIFICATION

I, Susan M. Dydek, RMC, Authority Secretary, hereby certify that the foregoing Resolution was duly adopted by the Riverside Sewerage Authority, in the Township of Riverside, County of Burlington, State of New Jersey, at the Regular Meeting held on the 13th day of July, 2026.


Susan M. Dydek, RMC
Authority Secretary

Messrs. Giovanetti, Horton and Mingin. Nays – None. Abstain – None. Absent – Messrs. Brickley and Conard. Motion carried.

Mr. Horton made a motion to adopt Resolution 2026 - #25 entitled, "Riverside Sewerage Authority A Resolution Authorizing the Award of a Contract for Bond Counsel" seconded by Mr. Mingin be approved. Upon roll call the vote was as follows: Ayes – Messrs. Giovanetti, Horton and Mingin. Nays – None. Abstain – None. Absent – Messrs. Brickley and Conard. Motion carried.

PUBLIC PORTION – (TECHNICAL):

Vice - Chairman Giovanetti opened the Public Portion - (Technical)

In seeing no members of the Public Present wishing to speak, **motion made by Mr. Horton, seconded by Mr. Mingin to close Public Portion (Technical) carried.**

OLD BUSINESS:

Riverside Sewerage Plant:

None.

Other:

1. Mindie Weiner (Riverside Tax Collector) on behalf of Jayson Love – 802 Devon Road – Leak Adjustment. After reviewing the documentation from New Jersey American Water Company, **Mr. Horton made a motion to credit the account 471 gallons which is the same amount that New Jersey American Water credited their account, seconded by Mr. Mingin carried.**

NEW BUSINESS:

1. Janice – 839 Bridgeboro neighbor complaint – water backing up at vent pipe.

CORRESPONDENCE:

1. State of New Jersey – Department of Environmental Protection – Authorization to Award.
2. Riverside Middle School – Thank you for award.

REPORTS:

PLANT:

Mr. Giovanetti reported that the Executive Director will give an update.

APPEALS

Mr. Horton had nothing to report.

REVENUE AND FINANCE:

Mr. Giovanetti reported that the third quarter bills are scheduled to be mailed this month.

STREETS:

Mr. Mingin had nothing to report.

INSPECTIONS:

Mr. Brickley was not in attendance.

EXECUTIVE DIRECTOR'S REPORT:

Executive Director Jeffrey Conard reported the following:

- A sinkhole was reported at the intersection of Harrison and Clay streets, which is currently covered by a steel plate.
- A camera inspection of the main line at the sinkhole site is scheduled for tomorrow to check for dirt infiltration, with a full repair by M&N scheduled for next Tuesday.
- The Executive Director reported a recent confrontation between Authority employees and a resident, Mr. John Stypinski, who reportedly harassed workers while they were performing their duties. The Authority Members discussed the incident, noting that Mr. Stypinski used derogatory language toward the staff. It was decided that the Authority's solicitor will draft a cease-and-desist letter to Mr. Stypinski, advising him to stop all contact with employees and instead direct any concerns to the plant directly. The Authority members agreed that if the behavior continues, they will pursue harassment charges. **Motion made by Mr. Horton, seconded by Mr. Mingin authorizing the Authority Solicitor to draft a Cease – and – Desist Letter to Mr. John Stypinski carried.**

The Executive Director's report is in file in the Secretary's Office.

Motion made by Mr. Mingin to accept the Executive Director's Report, seconded by Mr. Horton carried.

ENGINEER'S REPORT:

The Engineer's Report was submitted.


No questions or concerns were presented.

Motion made by Mr. Horton to accept the Engineer's Report, seconded by Mr. Mingin carried.

**RIVERSIDE SEWERAGE AUTHORITY
PLANT OPERATOR'S REPORT
AUTHORITY MEETING – JULY 13, 2026**

1. The Plant Performance Summary for June, 2026 is attached for review. The Residuals [Sludge] Management Summary for June, 2026 is also attached for review. Dewatered sludge [25 yds] were removed by the Seaside Waste Services Company for composting at the County facility.
2. Trouble log for June is attached.
3. Weekly collection system checks were performed in June. Cleaning of the collection system has also started.
4. No measurements were taking for the Secondary Digester Cover tilt during this reporting period. The Secondary Digester is not operating as designed. The Secondary Digester Dome requires methane gas produced in the Primary Digester for the secondary roof to float correctly.
5. Still injecting Poly Aluminum Chloride in the influent well of the flocs to assist with suspended solids settling out. This will assist in keeping our UVT number above 43 which is the lowest number for our UV system to function properly.
6. DEP inspection on June 16th. All went well.
7. Clarafloculator #2 is back in service. Case #26-06-05-1345-07/Operator #60.
8. Advised Ben to move forward with the building renovation of Building #2.

Respectfully Submitted,



JEFFREY M. CONARD
EXECUTIVE DIRECTOR

PLANT PERFORMANCE SUMMARY

June-26

PARAMETER	PERMIT	REPORTED		PARAMETER	PERMIT	REPORTED	
12 Month Rolling flow				12 Month Avg. Thershold CAP %			
Monthly Avg	Report	0.618	MGD	Mon Avg Conc	Report	62.00	%
FLOW, INFLUENT				NITRATE {AS N}, EFFLUENT Monthly			
Monthly Avg	Report	0.837	MGD	Mon Avg Conc	Report	28.30	MG/L
Daily Maximum	Report	1.097	MGD	Daily Max Conc	Report	28.30	MG/L
FLOW, EFFLUENT				E. COLI 2 / month			
Monthly Avg	Report	0.623	MGD	Monthly Avg	126/100 ml	4.12	/100ML
Daily Maximum	Report	1.125	MGD	Daily Max	Report	8.50	/100ML
5 DAY BOD, INFLUENT 3/month				FECAL COLIFORM, EFFLUENT Require Reuse Only			
Mon Avg Conc	Report	233.00	MG/L	Monthly Avg	200/100ML	3.10	/100ML
Weekly Avg Conc	Report	399.00	MG/L	Weekly Avg	400/100ML	3.10	/100ML
5 DAY BOD, EFFLUENT 3/month				BIOASSAY, EFFLUENT			
Mon Avg Loading	98 KG/D	18.03	KG/D	LC50 96 hr Acute	>50	0.00	%
Weekly Avg Loading	147 KG/D	20.57	KG/D	IC25 7 day Chronic	Report	0.00	%
Mon Avg Conc	30 MG/L	7.38	MG/L	CHLORINE PRODUCED OXIDANTS, EFFLUENT Monthly			
Weekly Avg Conc	45 MG/L	8.57	MG/L	Mon Avg Conc	Report	0.02	MG/L
5 DAY BOD REMOVAL EFFICIENCY 3/month				Daily Max Conc	Report	0.04	MG/L
Mon Avg Minimum	88.5	96.83	%	TEMPERATURE, INFLUENT Daily			
pH, INFLUENT Daily				Minimum	Report	21.7	DEG C
Minimum	Report	7.14	S.U.	Monthly Avg	Report	23.6	DEG C
Maximum	Report	7.76	S.U.	Maximum	Report	24.8	DEG C
pH, EFFLUENT Daily				TEMPERATURE, EFFLUENT Daily			
Minimum	6.00 S.U.	6.11	S.U.	Minimum	Report	20.9	DEG C
Maximum	9.00 S.U.	6.99	S.U.	Monthly Avg	Report	23.9	DEG C
TOTAL SUSP SOLIDS, INFLUENT 3/month				Maximum	Report	25.5	DEG C
Mon Avg Conc	Report	398.0	MG/L	DISSOLVED OXYGEN, EFFLUENT 3/month			
Weekly Avg Conc	Report	447.0	MG/L	Wkly Avg Conc [Mi	4.0 MG/L	5.44	MG/L
TOTAL SUSP SOLIDS, EFFLUENT 3/month				PHOSPHOROUS, EFFLUENT 1 / month			
Mon Avg Loading	113 KG/D	33.42	KG/D	Mon Avg Conc	Report	6.15	MG/L
Weekly Avg Loading	170 KG/D	34.20	KG/D	Weekly Avg Conc	Report	6.15	MG/L
Mon Avg Conc	30 MG/L	13.67	MG/L	COPPER, EFFLUENT Quarterly only			
Weekly Avg Conc	45 MG/L	13.90	MG/L	Mon Avg Conc	Report	Code=n	MG/L
TOTAL SUSP SOLIDS REMOVAL EFFICIENCY 3/month				Daily Max Conc	Report	Code=n	MG/L
Mon Avg Minimum	85	96.57	%	ZINC, EFFLUENT Quarterly Only			
OIL&GREASE, EFFLUENT Quarterly				Mon Avg Conc	Report	Code=n	MG/L
Mon Avg Conc	10 MG/L	Code=N	MG/L	Daily Max Conc	Report	Code=n	MG/L
Daily Max Conc	15 MG/L	Code=N	MG/L	Total Dissovled Solic Effluent 1/month			
Ammonia-Nitrogen {May-Oct}, Effluent				Mon Avg Conc	Report	484.0	MG/L
Mon Avg Loading	18.8 kg/d	18.27	KG/D	Daily Max Conc	Report	484.0	MG/L
Daily Max Loading	37.9 kg/d	20.37	KG/D	Bis(2-ethyhexyl)phthalate Quarterly only			
Mon Avg Conc	5 mg/l	7.48	MG/L	Mon Avg Conc	Report	Code=N	ug/l
Daily Max Conc	10 mg/l	8.49	MG/L	Daily Max Conc	Report	Code=N	ug/l
AMMONIA NITROGEN {NOV-APR}, EFFLUENT				Asbestos Filrous per Liter Semi-Annually			
Mon Avg Loading	75.7 KG/D	0.00	KG/D	Mon Avg Conc	Report	Code=N	Fiber per Liter
Daily Max Loading	151.4 KG/D	0.00	KG/D	Daily Max Conc	Report	Code=N	Fiber per Liter
Mon Avg Conc	20 MG/L	0.00	MG/L	Color Starting July 2024			
Daily Max Conc	40 MG/L	0.00	MG/L	Mon Avg Conc	Report	50.00	CU
Copper	Required		Quarterly	IC25 Chronic	Required		Semi- Annually
Zinc	Required		Quarterly	LC50 Acute	Required		Annually
Asbestos Filrous per Liter			Semi-Annua	Bis(2-ethyhexyl)phthalate Quarterly			

RESIDUALS MANAGEMENT SUMMARY

June-26

SLUDGE PRODUCED					RAW SLUDGE		
Total Gallons	0	gal	% Total Solids, minimum	2.6	%		
Average Gallons/Day	0	gpd	% Total Solids, average	3.4	%		
Total Dry Tons	0	dt	% Total Solids, maximum	3.9	%		
Average Dry Tons/ Day	0	dt/d	% Total Volatile Solids, minimum	55.40	%		
Total Metric Tons	0	mt	% Total Volatile Solids, average	69.30	%		
Average Metric Tons/Day	0	mt/d	% Total Volatile Solids, maximum	80.30	%		
			pH minimum	5.99	s.u.		
LIQUID SLUDGE REMOVED			pH maximum	7.62	s.u.		
Total Gallons	0	gal	sludge sample temperature, min	21.2	C		
Average Gallons/Day	0	gpd	sludge sample temperature, avg	23.1	C		
Total Dry Tons	N.R.	dt	sludge sample temperature, max	25.9	C		
Average Dry Tons/ Day	N.R.	dt/d	PRIMARY DIGESTER SLUDGE				
Total Metric Tons	N.R.	mt	% Total Solids, minimum	1.15	%		
Average Metric Tons/Day	N.R.	mt/d	% Total Solids, average	1.32	%		
% Total Solids, Minimum	N.R.	%	% Total Solids, maximum	1.51	%		
% Total Solids, Average	N.R.	%	% Total Volatile Solids, minimum	77.90	%		
% Total Solids, Maximum	N.R.	%	% Total Volatile Solids, average	78.90	%		
pH, Minimum	N.R.	s.u.	% Total Volatile Solids, maximum	80.80	%		
pH, Maximum	N.R.	s.u.	pH minimum	6.53	s.u.		
DEWATERED SLUDGE REMOVED			pH maximum	7.2	s.u.		
Total Gallons to Belt Press	0	gal	sludge sample temperature, min	20.6	C		
Average Gallons/Day	0	gpd	sludge sample temperature, avg	24.2	C		
% Total Solids, minimum	18.30	%	sludge sample temperature, max	26.8	C		
% Total Solids, average	18.90	%	SECONDARY DIGESTER SLUDGE				
% Total Solids, maximum	19.30	%	% Total Solids, minimum	3.08	%		
% Total Volatile Solids, minimum	80.70	%	% Total Solids, average	3.79	%		
% Total Volatile Solids, average	81.07	%	% Total Solids, maximum	4.36	%		
% Total Volatile Solids, maximum	81.50	%	% Total Volatile Solids, minimum	78.40	%		
Total Wet Cubic Yards Removed	100.00	cu yd	% Total Volatile Solids, average	79.33	%		
Average Wet Cubic yards/day	3.33	cy/d	% Total Volatile Solids, maximum	80.10	%		
Total Dry Tons	14.94	dt	pH minimum	6.42	s.u.		
Average Dry Tons/ Day	0.48	dt/d	pH maximum	6.94	s.u.		
Total Metric Tons	13.58	mt	sludge sample temperature, min	21.60	C		
Average Metric Tons/Day	0.44	mt/d	sludge sample temperature, avg	23.40	C		
OPERATIONS			sludge sample temperature, max	25.70	C		
Heat Exchange, Temp In, min	86.0	°F	VOLATILE SOLIDS REDUCTION				
Heat Exchange, Temp In, avg	90.6	°F	Raw to Secondary Digester, minimum	59.50	%		
Heat Exchange, Temp In, max	94.0	°F	Raw to Secondary Digester, average		%		
Heat Exchange, Temp Out, min	92.0	°F	Raw to Secondary Digester, maximum	59.50	%		
Heat Exchange, Temp Out, avg	100.0	°F					
Heat Exchange, Temp Out, max	110.0	°F					
Detention Time, Primary Digester	N.W.	days					
Detention Time, Secondary Digester	N.W.	days					
N.R. = None Removed			R.T.S. = Return To Service				
N.S. = Not Sampled			N.I.S. = Not In Service				
N.W. = Not Working							

June 2026 Trouble Log Summary

Date 6/1/2026	Report #	Address 519 Bridgeboro	Condition(s) Reported order complaint NJDEP Case # 26-05-19-1311-21	Condition(s) Found main clear oper.93	Manhole Checked MH112,115	Disposition Notified Superintendent
6/5/2026	26-075	839 Bridgeboro	Vent overflow	Main Slow	MH157,158,156,142	Flush/Vac/root cut sewer main
6/8/2026	26-076	537 Bridgeboro	Vent overflow	Main Clear	MH114,116	Notified Superintendent
6/9/2026	26-077	839 Bridgeboro	Vent overflow	Main Clear	MH157,158,156,142	Notified owner tennant
6/10/2026	26-078	624 Arndt Ave	Backflow into property	main clear	MH242,231,232,457	Notified owner tennant
6/11/2026	26-079	118 Jefferson	Vent Overflow	Main Clear	MH44,40,466	Notified owner tennant
6/18/2026	26-080	14 Zurburg way	Vent overflow	main clear	MH71,72	Notified Superintendent
6/30/2026	26-081	434 Bridgeboro	Vent overflow	Main Clear	MH113,112	Notified owner tennant
6/30/2026	26-082	712 Cleve and ave	Markout		MH397	Marked out Main

Mr. Brickley arrived at the meeting at 4:39pm.

MONTHLY FINANCIAL REPORT:

Treasurer Jack reported that the office is finalizing preparations with the accountant in order to begin the Audit with Mr. Lee.

A question was raised by Mr. Horton regarding a bill for "Auto Max," which the Executive Director clarified was actually "Auto Effects" for Kubota equipment maintenance.

Motion made by Mr. Horton to accept the Treasurer's Report, seconded by Mr. Brickley, carried.

BILLS AND EXPENDITURES:

Motion made by Mr. Horton, seconded by Mr. Brickley, that all bills and expenditures be paid carried.

July 13, 2026
03:54 PM

RIVERSIDE SEWERAGE AUTHORITY
Check Register By Check Id

Page No: 1

105

Range of Checking Accts: 01 TD GENERAL to 01 TD GENERAL Range of Check Ids: 5717 to 5752
Report Type: All Checks Report Format: Super Condensed Check Type: Computer: Y Manual: Y Dir Deposit: Y

Check #	Check Date	Vendor	Amount Paid	Reconciled/Void	Ref Num
5717	07/13/26	ALSEN005 ALS ENVIRONMENTAL	232.25		366
5718	07/13/26	ALSEN005 ALS ENVIRONMENTAL	1,190.50		366
5719	07/13/26	ALSEN005 ALS ENVIRONMENTAL	220.75		366
5720	07/13/26	ALSEN005 ALS ENVIRONMENTAL	204.00		366
5721	07/13/26	AUTOF005 AUTO FX	2,993.00		366
5722	07/13/26	BARTU005 BARTUK HOSE	305.60		366
5723	07/13/26	BURLI020 BURLINGTON FARM HOME & GARDEN	1,265.00		366
5724	07/13/26	CINTA005 CINTAS CORPORATION	4,706.08		366
5725	07/13/26	CUSTO005 CUSTOM ENVIRONMENTAL TECH-	3,278.85		366
5726	07/13/26	GRAIN005 GRAINGER	186.21		366
5727	07/13/26	HANKI005 HANKINS AUTO BODY	316.95		366
5728	07/13/26	INTER005 INTERSTATE WASTE SERV OF NJ IN	2,600.00		366
5729	07/13/26	JEFFR010 JEFFREY M CONARD	125.00		366
5730	07/13/26	JEFFR015 JEFFREY M CONARD	281.59		366
5731	07/13/26	LONGO005 LONGO ELECTRICAL CONTROLS LLC	5,239.70		366
5732	07/13/26	LOWTH005 LOWTHER'S SMALL ENGINE REPAIR	253.97		366
5733	07/13/26	MARME005 MARMERO LAW LLC	526.03		366
5734	07/13/26	NJAME005 N.J. AMERICAN WATER COMPANY	447.18		366
5735	07/13/26	NJAME010 N.J. AMERICAN WATER COMPANY	469.40		366
5736	07/13/26	ONECA005 ONE CALL CONCEPTS	164.60		366
5737	07/13/26	PARKE005 PARKER MCCAY PA	15,555.00		366
5738	07/13/26	PRINT017 Print & Mail Communications ll	1,908.90		366
5739	07/13/26	PSEG0005 PSE&G	12,590.63		366
5740	07/13/26	PSEG0005 PSE&G	11,610.41		366
5741	07/13/26	PUMPI005 PUMPING SERVICES INC	5,108.49		366
5742	07/13/26	RIVER025 RIVERSIDE NAPA AUTO PARTS	553.97		366
5743	07/13/26	SCHWE005 SCHWERING'S	52.99		366
5744	07/13/26	SNYDE005 SNYDER DISTRIBUTORS INC	277.00		366
5745	07/13/26	TREAS010 TREASURER, BURLINGTON COUNTY	9,751.01		366
5746	07/13/26	UNIVA005 UNIVAR SOLUTIONS	4,007.52		366
5747	07/13/26	USABL005 HD SUPPLY INC	429.15		366
5748	07/13/26	VERIZ005 VERIZON	316.03		366
5749	07/13/26	VERIZ010 VERIZON WIRELESS	72.49		366
5750	07/13/26	WBMAS005 W B MASON CO., INC	294.86		366
5751	07/13/26	WESTE005 WESTERN TERMITE & PEST CONTROL	121.24		366
5752	07/13/26	XEROX005 XEROX CORPORATION	13.16		366

Report Totals	<u>Paid</u>	<u>Void</u>	<u>Amount Paid</u>	<u>Amount Void</u>
Checks:	36	0	87,669.51	0.00
Direct Deposit:	0	0	0.00	0.00
Total:	36	0	87,669.51	0.00

Totals by Year-Fund Fund Description	Fund	Expend Total	Revenue Total	G/L Total	Total
General Fund	6-01	87,669.51	0.00	0.00	87,669.51
Total of All Funds:		<u>87,669.51</u>	<u>0.00</u>	<u>0.00</u>	<u>87,669.51</u>

PUBLIC PORTION (INFORMATIONAL):

In seeing that no members of the public wishing to speak, motion made by Mr. Horton and Mr. Mingin that Public Portion (Informational) be closed carried.

There being no further business to attend to, motion made by Mr. Brickley and Mr. Mingin that the meeting be adjourned and so declared by Vice-Chairman Giovanetti.


Susan M. Dydek, RMC
Authority Secretary